

QUESTIONS
FOR THE CITY OF SIOUX FALLS
MAIN LIFT STATION REPLACEMENT PROJECT
REQUEST FOR PROPOSAL
CIP – 23024

RFP date posted: September 30, 2016

Expiration date: October 28, 2016

Deadline for Questions 2:00 CT, October 21, 2016

Date updated: **October 24, 2016**

Questions submitted:

- 1) Please provide tech memo 4 and 5 describing how the piping will be connected.
 - a. Tech memos 4 and 5 have been posted
- 2) Please provide the approximate anticipated head condition for the pumps and the length of force main from the lift station to the point of gravity discharge.
 - a. 36" diameter force main
 - i. Approximate total length is 12,225 lf.
 - ii. Preliminary system head curve will be provided
 - b. 42" diameter force main –
 - i. Approximate total length is 12,100 lf.
 - ii. Preliminary system head curve will be provided