

Agenda
Electrical Board of Appeals and Examiners
Building Services Conference Room
Wednesday, January 5, 2011, 1:30 p.m.

Approval of Minutes of Last Meeting

New Business

1. Rose Grant obtained an electrical homeowner's permit to finish a two story addition onto her residence located at 210 W. 24th Street. Ms. Grant installed ThermoTile radiant floor heating mats in two bathrooms, a laundry and the foyer but failed to obtain an electrical rough-in inspection prior to placing the floor tile. Rough in inspections are required prior to floor placement for in-floor heating systems to verify that the mats are placed in accordance with the manufacturer's specifications, that the mats are not damaged prior to placement, that mats are not connected in series and that there are no nails or screws penetrating the floor and walls that can damage the heating wires. Ms. Grant will request that the Board review the acceptance of an Ohmmeter test for each of the radiant floor mats in lieu of disconnecting the lead wires, or removing and replacing each of the floors and radiant heating systems.
2. Grade Electrical Contractor's Exam No. 11-03
3. Grade Electrical Contractor's Exam No. 11-04

Adjournment

Accessibility. Upon request, accommodations for this hearing will be provided for persons with disabilities. Please contact the Planning and Building Services Department office at 367-8670, 48 hours in advance.

For questions concerning this hearing, please call (605) 367-8670 for assistance.