

**Agenda**  
**Electrical Board of Appeals and Examiners**  
**Building Services Conference Room**  
**Wednesday, March 2<sup>nd</sup>, 2011, 1:30 p.m.**

**Approval of Minutes of Last Meeting**

**New Business**

1. **Appeal No. 1-2011.** Jim Kuhle of Electric Construction has proposed the installation of a new Square D panelboard interior within an existing fused panel enclosure to be located at #1 W. Penmarch Place. The panelboard interior does carry a National Research Laboratory Testing (NRTL) certificate but the listing does not approve the insert into the existing panelboard enclosure. Adequate product evaluation and test data has not been submitted to staff for review to consider acceptance of the new insert into the existing panelboard. Mr. Kuhle will request that the Board review the new listed insert for approval into an existing panelboard enclosure.
2. Grade Fire Electrical Alarm Contractor Exam #11-01
3. Grade Fire Electrical Alarm Contractor Exam #11-02

**Adjournment**

**Accessibility.** Upon request, accommodations for this hearing will be provided for persons with disabilities. Please contact the Planning and Building Services Department office at 367-8670, 48 hours in advance.

**For questions concerning this hearing, please call (605) 367-8670 for assistance.**

