

Minutes
Mechanical Board of Appeals and Examiners
Building Services Conference Room
Wednesday, August 12, 2009 12 noon

Members Present

Mark Lamb, Mark Schempp, Ryan VanDerBill, Mark Weber

Members Absent

Mark deWit

Guests Present

Gary Klarenbeek, Steve Robertson, Ron Bell, Norm deWit, Jeff Kreiter

Approval of Minutes of Last Meeting

A motion was made by Mr. Lamb and a second was made by Mr. VanDerBill to approve the minutes of July 8, 2009. Yeses, 4. Noes, 0.

New Business

1. The file was opened for Appeal No.5-2009. Norm deWit of Associated Consulting Engineering, inc. requested that the board provide clarifications of Section 514 of the 2006 IMC, Energy Recovery Ventilation Systems. This section does not allow for an Energy Recovery Ventilator to exhaust Type II hoods. Mr. deWit wants to replace an existing ERV and add an additional Type II hood the new ERV.

A motion was made by Mr. VanDerBill and a second was made by Mr. Lamb to require Norm deWit to have the manufacture reclassify the unit as an (HRV) heat recovery ventilator for this Type II kitchen hood application. Yeses 4. Noes, 0.

2. Discussion on the 2009 code changes. Mr. Denny passed out one additional document to review of the potential code changes. The board also discussed having additional board meetings in the evenings or biweekly to review all the code changes.

***An audio tape of the meeting will be available at the City of Sioux Falls.**

Adjournment

A motion was made by Mr. VanDerBill and a second was made by Mr. Lamb to adjourn the meeting at 2:25 PM. Yeses, 4. Noes, 0.

Michael P Denny
Secretary