

Agenda
Mechanical Board of Appeals and Examiners
Building Services Conference Room
Wednesday September 14, 2016, 12 noon

Approval of minutes of last meeting

Unfinished business

None

New business

1. Election of new vice chairperson.
2. **Appeal BOA-ML-005593-2016.** David Wiederich is seeking clarification of IRC Section M1305.1 regarding the requirement for a minimum 30 inch by 30 inch level service space on the service side of an appliance, specifically regarding a condensing unit adjacent to a window well.

Accessibility. Upon request, accommodations for this hearing will be provided for persons with disabilities. Please contact the Planning and Building Services Department office at 367-8670, 48 hours in advance.

For questions concerning this hearing, please call (605) 367-8670 for assistance.